



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Kaishan Compressor USA							
	Model Number:	KRSD-100-115 VSD		Date:	06/30/20			
2	X Air-co	ooled Water-cooled		Type:	Screw			
				# of Stages:	1			
3*	Full Load Operating Pressure b		115	psig				
4	Drive Motor Nominal Rating		100	hp				
5	Drive Motor Nominal Efficiency		94.1	percent				
6	Fan Motor Nominal Rating (if applicable)		3	hp				
7	Fan Motor Nom	inal Efficiency	89.5	percent				
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	97.7		490	19.94				
	75.9		392	19.36				
	66.0		343	19.24				
	48.3		245	19.71				
	41.5		196	21.17				
9*		Total Package Input Power at Zero Flow c, d			kW			
10	Isentropic Effici	ency	72.26	%				
11	Specific Power (kW/100 ACFM)	Note: Graph is only a Note: Y-Axis Scale, 10 to 3:	175 200 225 250 275 300 325 Capacity (ACFM) visual representation of the data in \$5, + 5kW/100acfm increments if necesse, 0 to 25% over maximum capacity	Section 8	25 450 475 500 525			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.