



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacturer: Kaishan Compressor USA								
	Model Number:	KRSD-	30-125 VSD)		Date:	06/30/20		
2	X Air-cooled Water-cooled					Type:	Type: Screw		
						# of Stages:	1		
3*	Full Load Operating Pressure b				125	psig			
4	Drive Motor Nominal Rating				30	hp			
5	Drive Motor Nominal Efficiency				92.0	percent			
6	Fan Motor Nominal Rating (if applicable)				1	hp			
7	Fan Motor Nomin	nal Efficienc	y		83.5	percent			
	Input Power (kW)			Caj	pacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	31.3				142	22.04			
8*	26.1			114	22.89				
	23.5			99	23.74				
	18.1				71	25.49			
	15.9		4	57	27.89				
9*	Total Package Input Power at Zero Flow c, d			ď	0.0	kW			
10	Isentropic Efficiency				62.14		%		
	Specific Power (kW/100 ACFM)	35.00							
11	S S	15.00	25	50	75	100	125 150		
					(ACFM)		100		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate ecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
$\underline{\mathbf{m}^3 / \min}$	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1/- 10/0	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.