



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MODEL	DATA -	FOR (	COMPI	RESSEI	) AIR				
1	Manufacturer:	Kaishan Co	ompresso	r USA							
	Model Number:	KRSD-40-1	15 VSD				Da	ate:	(	06/30/20	
2	X Air-cooled Water-cooled						Ту	pe:		Screw	
							# of Stag			1	
3*	Full Load Operati	ing Pressure b		11:	5	11 01 2 44	<u>, , , , , , , , , , , , , , , , , , , </u>	psig			
4	Drive Motor Nominal Rating				40	)		hp			
5	Drive Motor Nominal Efficiency				92.	0	percent				
6	Fan Motor Nominal Rating (if applicable)				1		hp			hp	
7	Fan Motor Nomi	nal Efficiency			83.	83.5			percent		
	Input Power (kW)			С	apacity (	acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	38.9				198			19	19.65		
8*	32.4				158			20.51			
	29.1				139		20	20.94			
	22.7				99		22.93				
	19.1				79	)	24.18				
9*	Total Package Input Power at Zero Flow c, d				0.0					kW	
10	Isentropic Efficie	ntropic Efficiency				67.39				%	
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0 25	50 e: Graph is only	=	100	125	150	175	200	225	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES:



Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.