

## **COMPRESSOR DATA SHEET**

Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Kaishan Compressor	USA				
	Model Number: KRSP-350-125	Date:	6/30/2020			
2	Air-cooled X Water-cooled	Type:	Screw			
	X Oil-injected Oil-free	# of Stages:	1			
	Rated Capacity at Full Load Operating Pressure a,					
3*	e	1531.0	acfm <sup>a,e</sup>			
4	Full Load Operating Pressure b	125	psig			
5	Maximum Full Flow Operating Pressure <sup>c</sup>	125	psig <sup>c</sup>			
6	Drive Motor Nominal Rating	350	hp			
7	Drive Motor Nominal Efficiency	96.2	percent			
8	Fan Motor Nominal Rating (if applicable)	0.75	hp			
9	Fan Motor Nominal Efficiency	0.79	percent			
10*	Total Package Input Power at Zero Flow	65.4	kW <sup>e</sup>			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	259.70	$k\mathbf{W}^{d}$			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	16.96	kW/100 cfm <sup>e</sup>			
13	Isentropic Efficiency	88.55	Percent			

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

ROT 030.2

	Volume Flow Rate at specified conditions		Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org