




Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR													
1	Manufacturer:	Ianufacturer: Kaishan Compressor USA											
	Model Number: KRSP2-350-125 VSD							Date	<b>:</b>	07/12/21			
2	X Air-co	ooled	Water-coole	d				Туре	»:	Screw			
	X Lubri	cated	Oil Free					# of Stages	s:	2			
3*	Full Load Oper	Full Load Operating Pressure b				125		psig <sup>b</sup>					
4	Drive Motor Nominal Rating				350		hp						
5	Drive Motor Nominal Efficiency					96.2		percent					
6	Fan Motor Nominal Rating (if applicable)					15&4		hp					
7	Fan Motor Nominal Efficiency				9.	1.7&89.	1	percent					
8*	Input Powe			Capacity (acfm) <sup>a,d</sup>			Specific Power (kW/100 acfm) <sup>d</sup>						
	324.			1801		18.04							
	230.8				1261		18.30						
	201.5				1081		18.64						
	172.3				901		19.12						
	139.8			1	720		19.42						
9*	Total Package Input Power at Zero Flow c, d			, a	0.0		kW						
10	Isentropic Efficiency			81.18				%					
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 15.00 10.00 0	200 400  Note: Graph is Note: Y-Axis Scale, X-A	only a visu 10 to 35, +		tation of th	ts if necess		00 1800	2000			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>

NOTES:



- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

· ·	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1/- 10/0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

wember

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.