COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

1	Manufacturer: Kaishan	Compressor	USA			
	Model Number: KRSP2-4	Date		: 07/12/21		
2		ater-cooled		Type:	Screw	
<u></u>		l Free	107	# of Stages:	2 . b	
3*	Full Load Operating Pressure	125	psig			
4	Drive Motor Nominal Rating	400	hp			
5	Drive Motor Nominal Efficiency	96.2	percent			
6	Fan Motor Nominal Rating (if ap	r Nominal Rating (if applicable) 15&4			hp	
7	Fan Motor Nominal Efficiency		91.7&89.1	percent		
8*	Input Power (kW)		3.0 -		Specific Power kW/100 acfm) ^d	
	368.4		2179	16.91		
	302.1		1743	17.33		
	261.6		1525		17.15	
	195.3		1090	17.92		
	158.4		872	18.17		
9*	Total Package Input Power at Ze	0.0	kW			
10	Isentropic Efficiency		86.66	%		
11	35.00 30.00 30.00 25.00 25.00 15.00 15.00					
	10.00	500	1000 1500	2000	2500	

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



KAISHAN



ROT 031.2

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member			•		·	
	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
	$\underline{m^3} / \underline{min}$	<u>ft³ / min</u>	%	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8		
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Г 031.2	Above 15	Above 529.7	+/- 4	+/- 5		

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.